



1	2" Water Main	50'
2	3" Waste Sewer Line	70'
3	2 - 1 1/2" PVC/ELEC 70' to Bldg For Fire + Fiber + 25P wire pull will be 225' from A-B and should be underground rated	
4	2 - 4" PVC/Elec to underside of T-8	60'
5	1 - 3" PVC/Elec to underside of T-8	60'
6	6" Ductile Iron Pipe add valve at water tank outlet and thrust block add back flow preventer	50'
7	5 Bollards	

T-8 Utilities Drawing

T-8 Drawing: 1